

SSO Notification List											
April 2009											
Serial No.	Date of Occurrence	Location	Zip Code	Reason	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence
1	4/2/2009	646 S. Lakewood Avenue	21224	Rags, Roots & Grease	Inner Harbor	1:45	4:19 PM - 6:04 PM	Rags and Debris	Evidence of overflow	Used Electric Machine to Relieve Connection	Turned Over to CCTV
2	4/2/2009	3921 Boarman Avenue	21215	Rags & Grease	Gwynns Falls	1:36	6:44 PM - 8:20 PM	Gray Cloudy Water	136	Ran Electric Machine w/ Cutter Head	Turned Over to CCTV
3	4/3/2009	119 N. Bond Street	21231	Infilt./Inflow	Inner Harbor	1:00	12:00 PM - 1:00 PM	Gray Colored Water	1,500	Jetted Line with Pressure Truck & waited for Rain to Subside	Turned Over to CCTV
4	4/3/2009	1628 E. Baltimore Street	21231	Infilt./Inflow	Inner Harbor	1:10	11:50 AM - 1:00 PM	Gray Colored Water	2,500	Jetted Line with Pressure Truck	Turned Over to CCTV
5	4/3/2009	1800 E. Eager Street	21205	Heavy Rain	Patapsco	1:00	2:30 PM - 3:30 PM	Debris	Evidence of Overflow	No Action required, Rain Subsided	No Preventative Actions Reported
6	4/3/2009	1800 Falls Road	21201	Heavy Rain	Jones Falls	4:00	10:30 Am - 2:30 PM	Gray Water and Paper Debris	19,200	Subsided Over Time/Heavy Rain	No Preventative Actions Reported
7	4/3/2009	3200 Oakfield Avenue	21216	Rags & Trash & Heavy Rain	Gwynns Falls	5:00	10:00 AM - 3:00 PM	Gray Water	3,000	Jetted Line with Pressure Truck	No Preventative Actions Reported
8	4/3/2009	4200 Kathland Avenue	21207	Heavy Rain	Gwynns Falls	6:00	8:00 AM - 2:00 PM	Gray Water	5,400	Subsided Over Time/Heavy Rain	No Preventative Actions Reported
9	4/5/2009	418 Hutchins Avenue	21212	Rags, Roots & Grease	Herring Run	24:16	04/04/09 10:44 PM - 11:00 PM 04/05/09	Gray Water	3,000	Jetted Line with Pressure Truck	Turned Over to CCTV
10	4/5/2009	2200 Penrose Avenue	21223	Rags & Grease	Gwynns Falls	2:35	2:15 PM - 4:50 PM	Gray Colored Water	2,325	Jetted Line with Pressure Truck	Turned Over to CCTV
11	4/6/2009	3301 Liberty Heights Avenue	21215	Rags & Roots	Gwynns Falls	26:00	04/06/09 8:00 PM - 10:00 PM 04/07/09	Heavy Gray Water	3,120	Relieved M/L Choke with Cutting Machine & Pressure Truck	Turned Over to CCTV
12	4/13/2009	12 Edgevale Road	21210	Roots & Grease	Jones Falls	1:00	11:30 AM - 12:30 PM	Gray Water	120	Relieved M/L Choke with Pressure Truck	Turned Over to CCTV

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence
13	4/14/2009	5938 Northwood Drive	21212	Infilt./Inflow, Roots	Herring Run	5:15	1:50 PM - 7:05 PM	Gray Colored Water	945	Jetted Line with Pressure Truck	Turned Over to CCTV
14	4/16/2009	4205 Westview Road	21218	Rags & Roots	Herring Run	4:32	9:43 PM - 2:15 AM	Gray Water	270	Relieved M/L Choke with Pressure Truck	No Preventative Actions Reported
15	4/18/2009	2500 Grogan Avenue	21213	Rags & Grease	Inner Harbor	0:53	10:00 AM - 10:53	Sanitary Water, Grease & Rags	265	Relieved M/L Choke with Pressure Truck	Turned Over to CCTV
16	4/20/2009	1800 Falls Road	21201	Infilt./Inflow, Heavy Rain	Jones Falls	1:00	1:30 Pm - 2:30 PM	Gray Water	Evidence of Overflow	Waited for Rain to Subside	No Preventative Actions Reported
17	4/22/2009	402 S. Clinton Street	21224	Rags and Grease	Inner Harbor	1:30	8:30 PM - 10:00 PM	Gray Colored Water	Evidence of Overflow	Cleaned M/L with Electric Machine & Cables	Turned Over to CCTV
18	4/24/2009	3900 Harford Road	21218	Roots and Grease	Herring Run	2:00	7:30 AM - 9:30 AM	Gray Colored Water	1,200	Jetted Line with Pressure Truck	Turned Over to CCTV
19	4/25/2009	4500 Franklinton Road	21223	Rags, Trash and Grease	Gwynns Falls	1:44	12:30 PM - 2:14 PM	Gray Colored Water	1,040	Jetted Line with Pressure Truck	Turned Over to CCTV
20	4/25/2009	5529 Hillen Road	21239	Rags, Trash and Roots	Herring Run	2:10	1:20 PM - 3:30 PM	Gray Colored Water	650	Jetted Line with Pressure Truck	Turned Over to CCTV
21	4/28/2009	6300 Seaforth Street	21224	Rags and Trash	Patapsco	3:20	7:10 AM - 10:30 AM	Gray Colored Water	Evidence of Overflow	Jetted Line with Pressure Truck	Turned Over to CCTV
22	4/29/2009	2432 Edmondson Avenue	21223	Rags	Gwynns Falls	3:07	2:19 PM - 5:26 PM	Sewer Water, Paper & Debris	187	Relieved M/L Choke with Pressure Truck	Turned Over to CCTV
23	4/29/2009	5209 Catalpha Road	21214	Pipe Break	Herring Run	21:25	9:15 PM - 6:40 PM	Gray Colored Water	1,285	Jetted Line with Pressure Truck	Turned Over to CCTV
24	4/30/2009	3400 Reisterstown Road	21215	Rags	Gwynns Falls	2:00	12:40 PM- 2:40 PM	Heavy Gray Water	600	Relieved M/L Choke with Pressure Truck	Turned Over to CCTV
								TOTAL	46,743		

Work Order #
94585
94586
94625
94623
57157
94620
94632
94601
94677
94709
94783
94991

Work Order #
95083
95205
95261
95407
95456
95520
95586
95588
95675
58212
95719
95806